

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150781, Building Permit - Commercial  
Address: 2801 NE MCBAINE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Failed	Monday, December 21, 2015

### Corrective Action Required

1	Misc 1	-SUBMIT 3RD PARTY SPECIAL INSPECTION APPROVAL **3RD PARTY NOT FULLY APPROVED, STILL UNRESOLVED STEEL FRAMING ISSUES  **ADDENUM: THE TERMINATIONS OF THE LIGHT POLE WIRINGS INSIDE THE HANDHOLES MUST BE INSIDE BOXES; THE TERMINATIONS SHALL BE RATED FOR WET LOCATION
---	--------	--

### Comments: