



FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

December 22, 2015

CATHOLIC DIOCESE OF KC-ST JOE
130 NE MURRAY RD
LEES SUMMIT, MO 64081

Permit No: PRCOM20152917
Project Title: OUR LADY OF THE PRESENTATION SCHOOL - TYPE II HOOD
Project Address: 130 NW MURRAY RD, LEES SUMMIT, MO 64081
Parcel Number: 62130010800000000
Location: PRESENTATION PARISH LOT 1
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: ASSEMBLY FOR WORSHIP, RECREATION OR AMUSEMENT
Description: NEW TYPE II HOOD

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Rejected

1. For the Health Department inspection contact Deb Sees with the Jackson County Public Works Department, Environmental Health Division at (816) 847-7070. Health Department approval is required prior to receiving any type of Occupancy from the City of Lee's Summit.

Action required: Comment is for informational purposes.

2. For the Health Department review contact Deb Sees with the Jackson County Public Works Department, Environmental Services Division, at (816) 847-7070. Health Department approval is required prior to receiving any type of building permit from the City of Lee's Summit.

Action Required: This comment is for information purposes.

3. Inadequate information.

Action required: Provide electrical design or detailed scope of work that includes methods and materials.

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all

other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

TESTING THE OPERATION OF THE NEW HOOD AND THE EXSISTING ANSUL SYSTEM IS REQUIRED. TO SCHEDULE A TEST CONTACT THE FIRE DEPARTMENT AT 816-969-1300

2. WHEN WIRING THE NEW HOOD MAKE SURE TO INCLUDE THE HOOD LIGHTS ALONG WITH ALL ELECTRICAL UNDER THE HOOD AND NATURAL GAS SERVICE TO THE APLIANCES UNDER THE HOOD TO TERMINATE ON ANSUL ACTIVATION.
(VERIFIED AT TESTING)

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.