



100 N.E. Saint Luke's Blvd.
Lee's Summit, MO 64086
816-347-5000

The intent of this letter is to confirm that all 248 red emergency receptacles on 5th floor South were tested on emergency back up generators on December 15, 2015 by staff of Shaw Electric and witnessed by staff of Saint Luke's East Hospital. All red emergency outlets were tested for polarity and grounded in accordance to the National Electric Code.

Sean Sales

Facilities Management