

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20152451, Building Permit - Residential
Address: 417 SE MILL CREEK CIR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Mike Copeland	Not Ready	Tuesday, December 22, 2015

Corrective Action Required
1 Misc 1

DENIED FOR HAVING INCORRECT SUB-CONTRACTORS LISTED ON
THE PERMIT APPLICATION.

Comments: