

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20152446, Building Permit - Residential
Address: 420 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Mike Copeland	Not Ready	Tuesday, December 22, 2015

Corrective Action Required

1	Misc 1	Deinied for not having the correct sub-contractors listed on the permit application.
---	--------	--

Comments: