

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20151327, Building Permit - Residential
Address: 261 SE COYLE DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Failed	Wednesday, December 23, 2015

Corrective Action Required

1	Misc 1	-TOE NAIL ALL JOISTS TO 1ST FL TOP PLATES WITH 3-8D NAILS OR EQUIVALENT
		-PROVIDE ROOF VENTILATION PER CODE
		-UNDER THE REAR PORCH BEAM POINT LOAD (1ST FL REAR BED), INSTALL CANTILEVERED DOUBLE JOIST TO CARRY THIS POINT LOAD *****PER ENGINEER REPORT, PROVIDE BLOCKING AT THE CANTILEVERED SPACE TO SUBFLOOR*****
		**DO NO INSULATE
		RE-INSPECTION FEE

Comments: