

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20151716, Building Permit - Commercial  
Address: 401 NE COLBERN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	John Borns	Partial	Wednesday, December 23, 2015
Partial Correction 1      Misc 1		OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING LOCATIONS: [115] THRU [118] + AT EXISTING STAIR; <b>[114] AFTER CRIPPLES ARE SCREWED BOTH FLANGES AT HEADER ABOVE DOOR;</b>	
<b>Gas Piping Inspection - Commercial</b>	John Borns	Partial	Wednesday, December 23, 2015
Partial Correction 1      Misc 1		VISUAL INSPECTION OK AND GAS PIPING PRESSURE TEST HELD STEADY OR INCREASED AT >= 10 PSI FOR >=10 MIN. AT FOLLOWING PORTIONS OF GAS PIPING: FROM [140] SW TO UH-1 AND UH-2 IN NEW WASH BAYS; <b>NEW PIPING TO RTUs #6, #7, #8;</b>	

**Comments:**