

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20152121, Building Permit - Commercial
Address: 1601 SW MANOR LAKE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Mark Harding	Failed	Tuesday, December 29, 2015

Corrective Action Required

1	Misc 1	install uffer ground and isolate neutrals and grounds at panel. recall when complete Install final grade and sod, remove basketball goal from yard. per Planning dept. Fire ok
---	--------	--

Occupancy Inspection - Fire	Michael Weissenbach	Passed	Tuesday, December 29, 2015
--	------------------------	--------	----------------------------

Comments: