

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20141077, Building Permit - Commercial
Address: 3341 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Thursday, December 31, 2015

Partial Correction
1 Misc 1

FIRE CAULKING @ PLUMBING PENETRATIONS OF RATED WALLS
AT BATHROOM CABINET LOCATIONS AT FLOORS 1; 2; **3; 4**

Comments: