

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20152958, Building Permit - Commercial  
Address: 506 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Commercial</b>	John Borns	Failed	Wednesday, January 06, 2016

Corrective Action Required

1	Misc 1	SHAFT DIAMETER NOT PER APPROVED DRAWING.
---	--------	--

<b>Piers/Caissons Inspection - Commercial</b>	John Borns	Passed	Wednesday, January 06, 2016
---	------------	--------	-----------------------------

**Comments: CONTINGENT ON JB RECEIPT OF ENGINEER LETTER OK TO POUR WHEN READY FOUR PIERS AT >=4'-9" DEEP WITH BELL DIAMETER >=29".**