

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20151852, Building Permit - Residential

Address: 617 NW WILLOW DR, Unit:C, LEES SUMMIT, MO 64081617 NW WILLOW DR, Unit:B, LEES SUMMIT, MO 64081617 NW WILLOW DR, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	John Borns	Partial	Thursday, January 07, 2016

Partial Correction

1 Misc 1

GAS PIPING PRESSURE TEST HELD STEADY AT ≥ 10 PSI FOR ≥ 10 MIN. + VISUAL INSPECTION OK AT: UNIT "A" (NORTH); **UNIT "B" (CENTER);**

All Rough Inspection - Residential	John Borns	Partial	Thursday, January 07, 2016
---	------------	---------	----------------------------

Partial Correction

1 Misc 1

OK TO COVER WHEN READY AT: UNIT "A" (NORTH); **UNIT "B" (CENTER);**

*TGI DRAWING REQUIRED FOR FLOOR JOISTS; SUPPORT PEX AT 32" MAX INTERVALS

Comments: