

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152364, Building Permit - Commercial
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Electrical Inspection - Commercial	John Borns	Passed	Monday, January 11, 2016
Final Electrical Inspection - Commercial	John Borns	Passed	Monday, January 11, 2016

**Comments: RIGID CONCUIT TRENCHED FROM QUAZITE BOX TO SIGN; WIRE PULLED & TERMINATED.
SIGN IS LABELED PER UL. CONCRETE SLAB TO BE POURED AT BASE. NO ISSUES FOUND. CLOSE PERMIT.**