

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20151488, Building Permit - Residential
Address: 3106 SE 3RD TER, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mike Copeland	Failed	Tuesday, January 12, 2016

Corrective Action Required

1	Misc 1	-ESTABLISH FINAL GRADE, SOD, SPLASHBLOCKS -HEADROOM CLEARANCE, STAIRWAY TO BASEMENT, LIGHT FIXTURE IS IN THE REQUIRED HEADROOM CLEARANCE -GARAGE HAS NO POWER, CAN NOT INSPECT -REQUIRED TO HAVE CARBON MONOXIDE DETECTION ON FIRST FLOOR OUTSIDE BEDROOM
---	--------	--

Footing Inspection - Residential	Mike Copeland	Passed	Tuesday, January 12, 2016
---	---------------	--------	---------------------------

Comments: