

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20151850, Building Permit - Residential

Address: 618 NW WILLOW DR, Unit:C, LEES SUMMIT, MO 64081618 NW WILLOW DR, Unit:B, LEES SUMMIT, MO 64081618 NW WILLOW DR, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Friday, January 15, 2016

Corrective Action Required

1 Misc 1

INSPECTION OF THE SILL PLATE ANCHOR BOLTS BEFORE COVERING:

-ANCHOR ALL SILL PLATES WITHIN 12" OF BREAKS; EACH SHORT SILL PLATE NEEDS 2 ANCHORS

Comments: