

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20150890, Building Permit - Residential
Address: 3928 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Tuesday, January 19, 2016

Corrective Action Required

1	Misc 1	-INSTALL SIDEWALK; DRIVEWAY NOT APPROVED ON RECORD -FINAL GRADE, SOD, SPLASHBLOCKS -SEAL ABOVE METER AND FRONT LIGHTS -INSTALL GUARDRAIL AT STOOP WHERE MORE THAN 30" ABOVE GRADE -SCREW THE EMBEDDED METAL BRACE OF DECK DOOR INTO STUDS -FIREBLOCK FLOOR OPENING AT HYDRO TUB TRAP -GFCIs NOT TESTED AT THIS TIME
---	--------	---

Comments: