

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152308, Building Permit - Commercial
Address: 565 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Passed	Wednesday, January 20, 2016

Final Electrical Inspection - Commercial	John Borns	Failed	Wednesday, January 20, 2016
---	------------	--------	-----------------------------

Corrective Action Required
1 Misc 1

ELECTRICAL SERVICE ADDRESS IDENTIFICATION NOT FOUND
PERMANENTLY AFFIXED TO DISCONNECT ENCLOSURE.

Corrective Action Required
2 Misc 1

PER E.C. GROUND RING SERVES AS SUPPLEMENTAL GROUND
ELECTRODE BUT WAS NOT INSPECTED PRIOR TO BEING COVERED.

Comments: SERVICE RELEASED CONTINGENT ON PERMANENT ADDRESSING OF SERVICE EQUIPMENT.