

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRCOM20141080, Building Permit - Commercial
RESIDENCES AT NEW LONGVIEW
Address: 3371 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection Public Works	Jon Haley	Temporary C of O	Friday, January 22, 2016

Corrective Action Required

1

ALL PRIVATE HYDRANTS NEED THE TOP BONNET PAINTED SILVER
ALL VALVE BOXES NEED TO BE BROUGHT TO FINAL GRADE
ALL STORM BOXES NEED TO BE CLEANED OF TRASH AND DEBRIS
ALL INLET PROTECTION NEEDS TO BE CLEANED OF SILT

Comments: OCCUPANCY WILL BE GRANTED IF HYDRANTS ARE PAINTED