

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20141077  
**Address:** 3341 SW KESSLER DR, LEES SUMMIT, MO 64081  
**Inspected On:** Friday, January 22, 2016  
**Inspected By:** Michael WeissenbachMichael WeissenbachMark HardingMichael Weissenbach  
**Expiration Date:** 3/10/2016 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Alarm Test</b>	Michael Weissenbach	Passed	Friday, January 22, 2016
<b>Sprinkler - Flow Test</b>	Michael Weissenbach	Passed	Friday, January 22, 2016
<b>Occupancy Inspection - Codes Commercial</b>	Mark Harding	Temporary C of O	Friday, January 22, 2016

**Corrective Action Required:**

1      Misc 1      CODES- complete water heater and mop sink 1st floor in Janitor room.  
Clean roof top.

pending approval from other departments

Fire ok, Water ok, Pw ok for TCO

Tco granted .

**Occupancy Inspection - Fire** Michael  
Weissenbach

Passed

Friday, January 22,  
2016