



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20152703	Date:	January 25, 2016
Project Title:	THIRD STREET SOCIAL	Applicant:	
Location:	123 SE 3RD ST, LEES SUMMIT, MO 64063	ALLIANCE FIRE PROTECTION LLC	
Type of Work:		130 W 9TH AVE STE 101	
Occupancy Group:	A-2	KANSAS CITY, MO 64116	
Description:	INTERIOR ALTERATIONS FOR FULL SERVICE RESTAURANT - PROJECT INCLUDES 562 SF ADDITION FOR STORAGE AND COOLERS	Primary:	(913) 888-0647
Construction Type:	Type IIIB (Unprotected)		
Map Page:	195G		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.
EXSISTING SPRINKLER SYSTEM SHALL BE CURRENT WITH THE REQUIRED ANNUAL SERVICE/MAINTENENCE. DISPLAYING A CURRENT SERVICE TAG ON THE RISER. VERIFIED AT INSPECTION.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.