

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20151583, Building Permit - Residential  
Address: 262 SE COYLE DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mike Copeland	Failed	Thursday, January 28, 2016

Corrective Action Required

1	Misc 1	-SIDEWALK NOT APPROVED ON RECORD -FINAL GRADE, SOD, SPLASHBLOCKS
---	--------	---

**Comments:**