

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20151716, Building Permit - Commercial
Address: 401 NE COLBERN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Partial	Friday, January 29, 2016

Partial Correction
1 Misc 1

OK FOR USE & OCCUPANCY AT FOLLOWING SPACES: PHASE 1 SPACES [115]-[118]; WASH BAY ADDITION OK IF VACUUM BREAKER IS INSTALLED ON THREADED HOSE BIBB CONNECTION; **PHASE 2 INCLUDING [113] & [114];**

Comments: