

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20150974, Building Permit - Residential
Address: 3345 SW JESSIE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mike Copeland	Failed	Friday, January 29, 2016

Corrective Action Required

1	Misc 1	-INSTALL SPLASHBLOCKS 36 INCHES FROM FOUNDATION
		-MISSING SPINDLES MAIN STAIRS
		- OBTAIN LAWN SPRINKLER PERMIT

Comments: