

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20152944, Building Permit - Commercial  
Address: 221 NW CHIPMAN RD, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Commercial</b>	John Borns	Not Ready	Friday, January 29, 2016

Corrective Action Required  
1 Misc 1

**RE-BAR NOT IN PLACE FOR INSPECTION; SOME HOLES DRIILED  
OFF-CENTER; MINIMUM 3" CLEARANCE REQUIRED FROM  
RE-BAR TO DIRT AT BOTTOMS & BANKS.**

<b>Piers/Caissons Inspection - Commercial</b>	John Borns	Not Ready	Friday, January 29, 2016
---	------------	-----------	--------------------------

Corrective Action Required  
1 Misc 1

**RE-BAR NOT IN PLACE FOR INSPECTION**

**Comments:**