

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20150014, Building Permit - Commercial
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Passed	Friday, January 29, 2016

Comments: OK TO COVER SITE LIGHTING BURIED PVC ELECTRICAL CONDUIT AT SOUTH AND NORTH SIDES OF BUILDING. CONDUIT LESS THAN 18" DEEP IS TO BE PROTECTED WITH CONCRETE COVER.