

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152839, Building Permit - Commercial
Address: 20 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Passed	Monday, February 01, 2016

**Comments: RENOVATED SPACE OK FOR USE & OCCUPANCY CONTINGENT ON PROVIDING OF
CERTIFICATION TO FIRE DPET OF PERIODIC TESTING OF EMERGENCY CIRCUITS. CLOSE PERMIT.**