

# LaTona Architects

1600 Genessee, Suite 353 Kansas City, Mo. 64102

Phone 816-471-0044 Fax 816-753-8811

latonaarchitects@yahoo.com

Joe Frogge  
Codes Administration  
220 SE. Green St.,  
Lee's Summit, Missouri 64063

February 6, 2016

Re: Permit No. PRCOM20152917  
Our Lady of the Presentation School – Type II Hood  
130 NW Murray Rd.

Dear Joe,

Re: Sheet A01

Please delete the note on the drawings that says "MAINTAIN MINIMUM 3" CLEARANCE". It is not required for a type II hood.

This should allow the approval of the final inspection of the hood installation.

.

If you have any questions, my cell phone number is 816-305-8800 and our fax number is 816-753-8811.

Sincerely,

Vince LaTona