

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20152404, Building Permit - Residential
Address: 3337 SW JESSIE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Not Ready	Wednesday, February 10, 2016

Corrective Action Required

1	Misc 1	-PLEASE HAVE APPROVED PLAN ON SITE INSPECTION NOT COMPLETED WITHOUT APPROVED PLAN. BE ADVISED, ENGINEER WILL NEED TO ADDRESS ABSENCE OF BRACED WALL AT THE REAR DINING AREA. PLEASE CALL TO DISCUSS
---	--------	---

Comments: