

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152703, Building Permit - Commercial
Address: 123 SE 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|---|------------|----------|-----------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Underslab Plumbing Inspection - Commercial | John Borns | Partial | Thursday, February 11, 2016 |

Partial Correction
1 Misc 1

OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN,
WASTE, & VENT PIPING EXCEPT AT: MAIN BUILDING DRAIN N OF
DRINK/PANTRY [9], TROUGH DRAIN (9), AND MENS RR [12];

NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR
PRESSURE-TESTING PIPING SYSTEM.

Comments: