

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20152404, Building Permit - Residential
Address: 3337 SW JESSIE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Mike Copeland	Passed	Thursday, February 11, 2016

Gas Piping Inspection - Residential	Mike Copeland	Passed	Thursday, February 11, 2016
--	---------------	--------	-----------------------------

Gas Service Inspection - Residential	Mike Copeland	Passed	Thursday, February 11, 2016
---	---------------	--------	-----------------------------

All Rough Inspection - Residential	Mike Copeland	Failed	Thursday, February 11, 2016
---	---------------	--------	-----------------------------

Corrective Action Required

1	Misc 1	-INSTALL STRAPS AT GARAGE PORTAL PER PLAN AND NAIL SHEATHING 3" O.C. -INSTALL ANCHOR BOLTS IN GARAGE WITHIN 12" OF PLATE BREAKS. -REAR WALL BREAKFAST, REQUIRED TO HAVE A BRACED WALL PANEL MIN. 27 INCHES WIDE WITHIN 10 FEET OF THE CORNER, HAVE AN ENGINEER ADDRESS. -INSTALL HANGER FOR LVL OVER LIVING ROOM -HOOK BATH FAN VENTS -ANCHOR POSTS IN BASEMENT
---	--------	--

Comments: