

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152703, Building Permit - Commercial
Address: 123 SE 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Friday, February 12, 2016

Partial Correction
1 Misc 1

OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING EXCEPT AT: MAIN BUILDING DRAIN N OF DRINK/PANTRY [9] AND MENS RR [12]; **MAIN BUILDING DRAIN N TO BAR LATERAL + BAR AREA;**

NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.

Footing Inspection - Commercial	John Borns	Passed	Friday, February 12, 2016
--	------------	--------	---------------------------

Comments: OK TO POUR WHEN READY TRENCH FOOTING AT UTILITY ENCLOSURE. UFER G.E.C. CONNECTED TO RE-BAR CAGE.