

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20151238, Building Permit - Residential
Address: 265 SE COYLE DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|---------------|----------|------------------------------|
| Occupancy Inspection - Codes Residential | Mike Copeland | Failed | Wednesday, February 17, 2016 |

Corrective Action Required

| | | |
|---|--------|---|
| 1 | Misc 1 | -NO RECORD OF SIDEWALK INSPECTION FROM PUBLIC WORKS. -INSTALL SECURITY SCREWS REAR DOOR. |
|---|--------|---|

GARAGE WILL NEED INSPECTED AFTER IT IS RE ESTABLISHED.

Comments: