

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20152639, Building Permit - Commercial
Address: 5050 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Partial	Friday, February 19, 2016

Corrective Action Required

1	Misc 1	-INSTALL A BACKFLOW VALVE UPSTREAM OF THE WATER SUPPLY TO SODA MACHINE&FILTER
---	--------	--

Comments: