

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20152552, Building Permit - Residential  
Address: 1652 NE WOODLAND SHORES CIR, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Tuesday, February 23, 2016

### Corrective Action Required

1 Misc 1

#### FRAMING:

- MAIN FLOOR REAR EXTERIOR BRACE WALL NOT COMPLIANT. SEE PLAN. PLAN CALLS FOR TWO WINDOWS, NOT THREE
- FIREBLOCKING: FB BASEMENT WALL PER CODE (EVERY 10 FT AND FROM CEILING FUR-DOWN SPACE);
- SHIM GAP AT BOTTOM OF STUDS IN BASEMENT, ALONG BEDROOM&BATH

**\*\*OK TO INSULATE**

### Comments: