

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20152552, Building Permit - Residential
Address: 1652 NE WOODLAND SHORES CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Partial	Wednesday, February 24, 2016

Corrective Action Required

1 Misc 1

FRAMING:

-MAIN FLOOR REAR EXTERIOR BRACE WALL NOT COMPLIANT. SEE PLAN. PLAN CALLS FOR TWO WINDOWS, NOT THREE

****OK TO ROCK**

Comments: