

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20151735, Building Permit - Commercial  
Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mike Copeland	Passed	Friday, February 26, 2016

Partial Correction

1 Misc 1

O.R. #4, OKAY TO INSTALL GYP ON CEILING PENDING ACCESS IS PROVIDED TO INSPECT MECHANICAL DROPS.

O.R. #2 OKAY TO INSTALL GYP PENDING ACCESS TO INSPECT DROPS

Corrective Action Required

2 Misc 1

WEST COORIDOR, LABEL ALL ABOVE CEILING SYSTEMS PIPING, MED GAS, DOMESTIC WHERE THEY PENETRATE WALLS

**Comments:**