

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20151850, Building Permit - Residential

Address: 618 NW WILLOW DR, Unit:C, LEES SUMMIT, MO 64081618 NW WILLOW DR, Unit:B, LEES SUMMIT, MO 64081618 NW WILLOW DR, Unit:A, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Residential</b>	John Borns	Partial	Tuesday, March 01, 2016

Partial Correction

1 Misc 1

PER 12/21/15 TELECON W/ DON SWOFFORD BASEMENT FLOOR SLAB AT (SOUTH) UNIT "A" HAS BEEN POURED WITHOUT UNDER-SLAB PLUMBING INSPECTION UNINTENTIONALLY.

Partial Correction

2 Misc 1

**OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING AT: UNIT "A";**

**NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.**

**Comments:**