

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20150016, Building Permit - Commercial
Address: 518 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|--|------------|----------|---------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| All Rough Inspection - Commercial | John Borns | Partial | Wednesday, March 02, 2016 |

Partial Correction
2 Misc 1

AFTER FIRE-BLOCKING IS COMPLETED OK TO COVER WHEN READY FRAMING AND ENCLOSED SYSTEMS AT: WALLS ONLY AT [C102] LOBBY AND [C111] KITCHEN; CEILING AND WALLS AT [C109] DINING, [C115], [C116], [C119], [C120];

Corrective Action Required
4 Misc 1

IBC 700: IN WOOD-FRAMED STRUCTURE FIRE-BLOCK ALL LEVEL-TO-LEVEL OPENINGS. ANY HOLES OR DISCONTINUITIES IN TOP & BOTTOM PLATES, TOPS & BOTTOMS OF CHASES / DEAD SPACES, INTERFACES OF WALLS WITH FLOOR / CEILING / FUR-DOWN SPACES

Partial Correction
5 Misc 1

OK TO COVER WHEN READY WALLS AND CEILING AT TIE-IN OF CORR [205] @ (B1)

Comments: