

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20160111, Building Permit - Residential
Address: 300 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection - Residential	Khanh Nguyen	Passed	Thursday, March 03, 2016
Underslab Plumbing Inspection - Residential	Khanh Nguyen	Passed	Thursday, March 03, 2016
Water Service Inspection - Residential	Mike Copeland	Partial	Thursday, March 03, 2016

Comments: