

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20150016, Building Permit - Commercial
Address: 518 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Thursday, March 03, 2016

Corrective Action Required

1 Misc 1

IBC 700: IN WOOD-FRAMED STRUCTURE FIRE-BLOCK ALL LEVEL-TO-LEVEL OPENINGS. ANY HOLES OR DISCONTINUITIES IN TOP & BOTTOM PLATES, TOPS & BOTTOMS OF CHASES / DEAD SPACES, INTERFACES OF WALLS WITH FLOOR / CEILING / FUR-DOWN SPACES.

Partial Correction

2 Misc 1

OK TO COVER WHEN READY FRAMING AND ENCLOSED SYSTEMS AT: WALLS ONLY AT [C102] LOBBY AND [C111] KITCHEN; CEILING AND WALLS AT [109] DINING, [C115], [C116], [C119], [C120];
WALLS @ [125], [126], [127];

Comments: