

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20150016, Building Permit - Commercial  
Address: 518 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Friday, March 04, 2016

Partial Correction  
1 Misc 1

**GWB AT 1 HR FIRE-RATED WALLS: OK TO TAPE, MUD, &  
FIRE-SEAL WHEN READY 5/8" TYPE X GWB INSTALLATION @  
FOLLOWING LOCATIONS: WALLS @ [119] & [120];**

<b>All Rough Inspection - Commercial</b>	John Borns	Partial	Friday, March 04, 2016
--	------------	---------	------------------------

Corrective Action Required  
1 Misc 1

IBC 700: IN WOOD-FRAMED STRUCTURE FIRE-BLOCK ALL LEVEL-TO-LEVEL OPENINGS. ANY HOLES OR DISCONTINUITIES IN TOP & BOTTOM PLATES, TOPS & BOTTOMS OF CHASES / DEAD SPACES, INTERFACES OF WALLS WITH FLOOR / CEILING / FUR-DOWN SPACES.

Partial Correction  
2 Misc 1

OK TO COVER WHEN READY FRAMING AND ENCLOSED SYSTEMS AT: [C102] LOBBY; [104] CORRIDOR; [109] DINING; [C111] KITCHEN + VESTIBULE @ SW; [114] CORRIDOR; [C115], [C116], [C119], [C120]; [C125]; [C126]; [C127];

**Comments:**