

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20150531, Building Permit - Residential

Address: 3353 SW JESSIE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-ADA Inspection	Brice Lawson	Partial	Friday, March 04, 2016

Informational

1 The forms are set and the rock has been compacted.

PW-Sidewalk Inspection	Brice Lawson	Partial	Friday, March 04, 2016
------------------------	--------------	---------	------------------------

Corrective Action Required

1 An ADA panel is required for your sidewalk crossing.

The plot plan shows a sidewalk ending at the curb. The curb will need to be removed to install an ADA ramp.

Informational

2 The sidewalk forms are set and the rock has been compacted.

PW-Public Curb Inspection	Brice Lawson	Passed	Friday, March 04, 2016
---------------------------	--------------	--------	------------------------

Informational

1 The curb forms are set and the dowels are in place.

Comments: