

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152126, Building Permit - Commercial
Address: 600 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Failed	Friday, March 04, 2016

Corrective Action Required

1	Misc 1	INSTALL LIGHT FIXTURES @ 1ST & 2ND FLOORS
---	--------	---

Corrective Action Required

2	Misc 1	SECURE MC CABLES WITHIN 12" OF ENTRY TO BOXES
---	--------	---

Corrective Action Required

3	Misc 1	CLOSE ELECTRICAL BOXES
---	--------	------------------------

Comments: CALL FOR RE-INSPECTION WHEN READY.