

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20141075, Building Permit - Commercial
Address: 3321 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mike Copeland	Not Ready	Monday, March 07, 2016

Corrective Action Required

1	Misc 1	FOURTH FLOOR, FOUR NORTH UNITS INSTALL ARRESTORS FOR LAUNDRY THIRD FLOOR, SOUTH EAST UNIT CHECK MECH CLOSET PENETRATION 2ND FLOOR, INSTALL MISSING GFCI KITCHEN, FIX GFCI, INSTALL GUARD LOWER LEVEL, COMPLETE PLUMBING, CHECK ARRESTORS FOR DISHWASHER MAKE SURE ALL MONOXIDE DETECTORS, SMOKE ALARMS, EMERGENCY LIGHTS, SPRINKLER HEADS ARE USABLE.
---	--------	---

Occupancy Inspection - Fire	Joe Dir	Not Ready	Monday, March 07, 2016
--	---------	-----------	------------------------

Comments: