

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152126, Building Permit - Commercial
Address: 600 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Tuesday, March 08, 2016

Corrective Action Required
1 Misc 1

**AT 1ST FLOOR INSTALL TWO SLACK WIRES ON LAY-IN LIGHT
FIXTURE. CALL FOR RE-INSPECTION.**

OK TO COVER WHEN READY CEILING AT 2ND FLOOR.

**AFFIX PERMANENT SIGN ON WALL BELOW CEILING INDICATING
ELEVATOR DISCONNECT SWITCH IS ABOVE CEILING.**

Comments: