

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20151716, Building Permit - Commercial
Address: 401 NE COLBERN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Wednesday, March 09, 2016

Partial Correction
1 Misc 1

OK TO COVER WHEN READY ACT CEILING FRAMING +
ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: 115-118; 114;
PHASE 3 AREA EXCEPT **LEAVE OUT TILE WHERE 5 MISSING EM
LIGHT FIXTURES ARE TO BE INSTALLED -- FULL PATH FROM MC
WIRING SOURCE TO FED EM FIXTURE.**

Comments: