

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152126, Building Permit - Commercial
Address: 600 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Passed	Wednesday, March 09, 2016
Occupancy Inspection - Fire	Joe Dir	Passed	Wednesday, March 09, 2016
All Rough Inspection - Commercial	John Borns	Passed	Wednesday, March 09, 2016
Above Ceiling Inspection	John Borns	Passed	Wednesday, March 09, 2016

Comments: NO ISSUES FOUND ON FINAL INSPCETION. PROVIDE COPY OF STATE ELEVATOR INSPECTION APPROVAL. CHECK ELECTRICAL WHIP HANGING IN PIT; REMOVE IF NOT REQUIRED. CLOSE PERMIT.