

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152944, Building Permit - Commercial
Address: 221 NW CHIPMAN RD, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|---|------------|----------|--------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Final Building Inspection - Commercial | John Borns | Passed | Thursday, March 10, 2016 |

Comments: Building piers were failed for pour on 1/29/2016; not requested for re-inspection. Third-party report of observation was received later. Interior face of exterior walls of building have been sheathed in advance of (now requested) final inspection and merchandise has been paced against exterior walls. Condition of concealed structure is unknown. No issues found on structure remaining exposed. Close permit.