

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20160469, Building Permit - Residential
Address: 628 NW JACOB DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Not Ready	Monday, March 14, 2016

Corrective Action Required

1 Misc 1

ELECTRICAL SERVICE ADDRESS IDENTIFICATION AT METER /
DISCONNECT NOT FOUND AFFIXED TO ENCLOSURE. PLACE
PERMANENT ADDRESS LABEL ON SIDE OF PEDESTAL FACING
STREET ON WHICH SERVICE IS ADDRESSED.

Corrective Action Required

2 Misc 1

TWO GROUND RODS FOUND DRIVEN BUT NO CONNECTION
FOUND TO SERVICE EQUIPMENT

Comments: SERVICE PEDESTAL SHOULD BE SET PLUMB.