
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20152552, Building Permit - Residential

Address: 1652 NE WOODLAND SHORES CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Brice Lawson	Partial	Monday, March 14, 2016

Corrective Action Required

- 1 The driveway forms need to be adjusted for proper cross slope. The rock needs to be compacted.

PW-Sidewalk Inspection	Brice Lawson	Partial	Monday, March 14, 2016
------------------------	--------------	---------	------------------------------

Corrective Action Required

- 1 The sidewalk forms need to be adjusted and the rock needs to be compacted.

Comments:
