

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160416, Building Permit - Commercial  
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	John Borns	Passed	Tuesday, March 15, 2016
<b>Final Electrical Inspection - Commercial</b>	John Borns	Passed	Tuesday, March 15, 2016
<b>Electrical Service Inspection - Commercial</b>	John Borns	Passed	Tuesday, March 15, 2016

**Comments: DIRECT-BURIED CABLE IN PLACE IN 40"+ TRENCH FROM METER POST TO JOB TRAILER. SERVICE GROUNDING IN PLACE. NO ISSUES. RELEASE SERVICE. CLOSE PERMIT.**